

SAFETY CONCERN	SUBJECT	INITIATED BY DATE	SUPERVISOR DATE OF ANSWER	DATE REC'D BY COMM. ASSIGNED BY	COMMENTS	SETTLEMENT DATE	METHOD 1, 2, 3
88-46	BLDG. 444	[REDACTED] 3-17-88	R. KLENZ 3-17-88	5-5-88	CLOSED	5/3/88	
88-47	BLDG. 777 HOLE IN FLOOR TRIPPING HAZARD	[REDACTED] 2-25-88	R. QUAYLE 2-26-88	N/A 2/88	CLOSED OUT	2/26/88	1
88-48	Bldg 444 air temp.	[REDACTED] 4-25-88	R. NEST 4-26-88	N. JAMES D. WISE 5-5-88	CLOSED OUT	6/10/88	
88-49	Bldg 777 air temp	[REDACTED] 4-21-88	G. CHURP 4-28-88	N. JAMES R. NAUL 5-5-88	CLOSED OUT	6/10/88	
88-50	BLDG. 444 - VALVE VALVES NOT MONITORED FOR POSSIBLE CONTAM.	[REDACTED] 4/22/88	E. ENGLISH 5/3/88	G. SWENSON D. WISE 5/5/88	CLOSED OUT	5/24/88	
88-51	BUILDING 779 LOCKER ROOM, RESTROOM & SHOWER - 1ST FLOOR - DIRTY -	[REDACTED] 2-18-88	K. LONDON 3-16-88	J. SHU 3/88		3/88	
88-52	BLDG 444 VENT SYSTEM DIRTY POSSIBLY CONTAMINATED	[REDACTED] 2-5-87	B. HEIT 2-11-87	N/A 2/88	CLOSED OUT	2/11/87	
88-53	BLDG. 444 EXHAUST SYSTEM INADEQUATE	[REDACTED] 2-5-87	C. DEBORSKI 2-11-87	N/A 2/88	CLOSED OUT	2/11/87	
88-54	BLDG, 444 BOOSTER EXCHANGE SYSTEM	[REDACTED] 2-13-87	J. KOELMEL 2-16-87	N/A 2/88	CLOSED OUT	2/16/87	

CLOSED

JOINT COMPANY/UNION SAFETY COMMITTEE CONCERN FORM [Use Black Ink Only]

CASE #: 88-052

ASSIGNED TO: UNION _____

DATE _____

COMPANY: _____

DATE _____

EMPLOYEE NAME _____

EMPLOYEE # _____

DEPT TOOL GRIND

BLDG 444

PHONE _____

SHIFT ~~DAY~~ Day

I HAVE PREVIOUSLY DISCUSSED THIS CONCERN WITH MY SUPERVISOR: YES NO

CONCERN [BRIEFLY] VENTILATION SYSTEM IN OUR AREA IS FILTHY.

THIS HAS BEEN BROUGHT UP AT SEVERAL SAFETY MEETINGS.

PROMISES TO CLEAN THIS SYSTEM HAVE NOT BEEN KEPT.

I WANT A DEFINITE DATE FOR COMPLETION OF THIS SET

AND ALSO WANT COMPLETE ASSURANCE THAT SAID SYSTEM IS

NOT CONTAMINATED

[Redacted]

2-5-87
Date

IMMEDIATE SUPERVISOR RESPONSE [WITHIN 5 WORKING DAYS] _____

JANITORIAL HAS CLEANED THE VENTILATION SYSTEM ⁽²⁻⁹⁻⁸⁷⁾

RADIATION MONITORING HAS CHECKED FOR

RADIATION IT WAS NEGATIVE. (2-11-87) Results are

available.

[Signature]
Supervisor Signature

2-11-87
Date

[Signature]
Direct Report Manager Signature

2/11/87
Date

I AM SATISFIED WITH THE RESULTS.
 I AM NOT SATISFIED. REFERRAL TO THE JCUSC FOR INVESTIGATION BECAUSE:

NOTE: Timeliness in completing this form is of the utmost importance.

Distribution: Safety Committee - Supervision - Employee - Union Steward

032013

Maint. is not handling S.C.'s as a
priority.

also Harold Bryan is not answering
S.C.'s properly.